

Modbus Protocol for Universal Xplorer Industrial and Telecom Monitors (UXIM) and (UXTM) Battery Monitor Reference Guide



7775 West Oakland Park Blvd
Sunrise, FL 33351
Tel: 954-377-7101
www.alber.com
4200-102

Modbus Protocol for Universal Xplorer Industrial and Telecom and Monitors (UXIM) and (UXTM) Battery Monitor Reference Guide

Document Revision	3
Part Number	4200-102

Revision History

Revision	Date of change	Description of change	By
1.00	7/20/2010	Initial Document Creation	CC
1.10	8/24/2010	Added 25DEH and 25DFH for R-test alarm disable timer. Restructure System Status section and redefined. Added String status registers 0181H.	ED
1.20	10/4/2010	Updated Unit Information Section by adding additional registers to accommodate the amount of data.	CC
1.30	10/6/2010	Added 15 more string names to section 2.5	CC
1.40	10/7/2010	Edited section 2.3 Status Register to use bits for status	CC
1.50	7/19/2011	Added document number, TOC and formatted entire guide	CC
1.60	9/12/2011	New title and marketing updates	CC
1.70	3/08/2012	Added section 4 Alarm Type and PCB Revision/Version Format Appendix	CC
1.80	10/02/2012	Added UXIM throughout guide. Updated; ground fault current, ambient temperature, thresholds, and intertier configuration.	MS
1.90	11/05/2012	Added UXIM charger cable resistance information.	MS
2.00	06/26/2013	Added discharge duration and note.	MS
2.10	08/23/2013	Added ground fault resistance information, for configuration and alarm types.	MS
2.20	03/14/2014	Added a new category called Enables, for the configuration section.	MS
2.21	07/17/2014	Add registers (34543 – 34545) for resistance test starting time Add registers (39711 – 39966) for resistance baseline values Add registers (35122 – 35375) for intercell baseline values Add bit 9 in register 30385 for minor alarm status Add register (39027 – 39030) for major/minor alarm status Add registers (39043 – 39097) for minor alarm events Add registers (49027 – 49053) for minor alarm threshold Add register 49062 for resistance alarm type. Add registers (49063 – 49070) for major/minor alarm setup.	CC, MS

		Add registers (49082 – 49116) for digital input setups and names. Add registers (49134 – 49161) for sequential major alarm thresholds.	
2.22	8/5/2014	Add bit 12 for the intertier alarm status, enable and latch registers. Add bit 13 for the cell to ambient alarm status, enable and latch registers. Add bit 14 for the thermal runaway cell to ambient alarm status, enable and latch registers. Add bit 15 for the thermal runaway float currentt alarm status, enable and latch registers.	XB
2.23	11/17/2014	Add alarm ID 15 for digital input alarms in section 4.1	XB
2.24	04/2/2015	Updated information in the Modbus Protocol (ASCII Frame) (Address and Baud Rate) in section 1. Updated data address for R-test remaining time of alarm disable.	MS
2.25	10/13/2015	Updated Alarm Page Register data address information in the Status Registers section.	MS
3	02/15/16	Updated revision number from 1.08 to 2. This was done so documentation can be added to the Agile/LES system. Also updated the copyright year from 2015 to 2016	MS

Albér Modbus Protocol for Universal Xplorer Industrial and Telecom and Monitors (UXIM) and (UXTM) Battery Monitor
Reference Guide,
Part Number 4200-102

©2016 Albér, 7775 West Oakland Park Blvd, Sunrise, FL 33351 USA

No part of this document may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying and recording for any purpose, without the express written permission of AlbérCorp.

Information in this document is subject to change without notice.

Trademarks

The first instances of registered trademarks or trademarks of AlbérCorp and other companies are annotated above using the ® and ™ symbols. For ease of reading, these symbols do not appear in the remainder of this document.

Printed in the United States of America.

Note: Some of these features described in this Modbus Protocol Reference Guide are only implemented in the latest firmware release. Verify that you have the latest version of firmware for utilization of all features.

Albér Customer Service

Albér Customer Service is available Monday to Friday, 8:00AM to 4:30PM Eastern Time.

Telephone: (954) 377-7101
Email: service@alber.com
Website: www.alber.com

Corporate Office Address:
Albercorp
7775 West Oakland Park Blvd
Sunrise, FL 33351 USA

SOFTWARE LICENSE AGREEMENT

READ THESE TERMS AND CONDITIONS CAREFULLY BEFORE ATTEMPTING TO DOWNLOAD, INSTALL, OR USE THE SOFTWARE. BY DOWNLOADING, INSTALLING, OR USING THE SOFTWARE, YOU AGREE TO BE BOUND BY THESE TERMS AND CONDITIONS. IF YOU DO NOT ACCEPT THESE TERMS AND CONDITIONS, DO NOT DOWNLOAD, INSTALL, OR USE THE SOFTWARE. IN SUCH A CIRCUMSTANCE, THE SOFTWARE MAY BE RETURNED WITHIN THIRTY (30) DAYS OF YOUR RECEIPT FOR A FULL SOFTWARE REFUND. YOU REPRESENT THAT YOU (I) ARE NOT LOCATED IN, UNDER THE CONTROL OF, OR A NATIONAL RESIDENT OF ANY COUNTRY TO WHICH THE UNITED STATES HAS EMBARGOED GOODS, (II) ARE NOT ON THE U.S. TREASURY DEPARTMENT'S LIST OF SPECIALLY DESIGNATED NATIONALS, (III) ARE NOT ON THE U.S. COMMERCE DEPARTMENT'S LIST OF DENIED PERSONS, OR (IV) ARE NOT OTHERWISE PROHIBITED BY U.S. LAW FROM RECEIVING OR USING THE SOFTWARE (COLLECTIVELY "EXPORT RESTRICTIONS"). IF YOU DO NOT HAVE AUTHORITY TO ACCEPT THIS AGREEMENT FOR YOUR ORGANIZATION, IT IS YOUR OBLIGATION TO ENSURE THAT AN AUTHORIZED INDIVIDUAL MAKES THE DETERMINATION THAT YOUR ORGANIZATION IS NOT SUBJECT TO THE ABOVE EXPORT RESTRICTIONS PRIOR TO DOWNLOADING, INSTALLING, OR USING THE SOFTWARE.

This Software License Agreement ("Agreement") is a legal agreement between you and Albér Corp., a Florida, United States of America, corporation, ("Albér"). Albér's software, including enhancements, upgrades, and any future releases, if provided, is made available exclusively for use with the associated Albér products (the "Products"). The foregoing, including any accompanying program(s), documentation, images, animation, and text incorporated therein, (collectively "Software"), is provided solely for commercial and industrial use under the license terms specified herein.

GRANT OF RIGHTS: Provided that you comply with all of the terms of this Agreement, Albér grants a non-exclusive, non-transferable license to you to install and use the Software solely for use with Products as provided for herein. You represent and warrant that you will not use the Software in violation of applicable laws and regulations or where such use detrimentally affects Albér's rights in the Software or subjects Albér to liability. You assume responsibility for the selection of the Software to achieve your intended results, and for the installation, use, and the results obtained from the Software. Provided that you have paid the applicable license fees, you may use (i) BMDM with SQL, on one server on one site, with a maximum of two hundred (200) users; (ii) all other Software, an unlimited number users per site. Any other operation of the Software at any time shall constitute a material breach of this Agreement and shall terminate this license as provided for below. By use of the Software, you agree that Albér may, at its option, perform an audit of your usage of the Software to determine the number of servers and Products that are using the Software.

TERMINATION OF LICENSE: Your license is automatically terminated if you: (1) use the Software with anything other than Products, (2) attempt to copy or reconstruct any part of the object code, source code, or algorithms, (3) attempt to decompile, disassemble or reverse engineer the Software, in whole or in part, or otherwise attempt to derive the source code of the Software, (4) provide, disclose, sell, rent, lease, license, sublicense, or otherwise transfer or assign the Software to any third party, (5) use the Software in excess of the licensed coverage purchased, (6) write or develop any derivative software or any other software program based upon the Software, (7) modify or alter the Software, or (8) fail to comply with any other license terms. You may elect to terminate this license at any time by destroying the Software together with all copies and any portions thereof in any form.

LIMITED WARRANTY: Albér represents that it has the right and authority to grant the license herein. Albér warrants solely to you for a period of thirty (30) days from the date of Albér shipment or distribution that the distribution media (if supplied) on which the Software is furnished under normal use will be free from defects in material and workmanship and the Software will substantially conform to Albér published

documentation. EXCEPT FOR THE ABOVE EXPRESS WARRANTIES, THIS SOFTWARE IS PROVIDED "AS IS" WITHOUT WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING, WITHOUT LIMITATION, IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR INTENDED PURPOSE. ALBÉR DOES NOT WARRANT THAT THE SOFTWARE FUNCTIONS WILL MEET YOUR REQUIREMENTS OR THAT THE SOFTWARE WILL OPERATE UNINTERRUPTED OR ERROR FREE.

LIMITATION OF REMEDIES: Albér's entire liability and your exclusive remedy arising from use or inability to use the Software is: (1) The replacement of any distribution media not meeting Albér's warranty, or (2) If Albér is unable to provide you a replacement that conforms to Albér's warranty, to refund the purchase price. **THE REMEDIES SET FORTH IN THIS AGREEMENT ARE EXCLUSIVE.**

LIMITATION OF DAMAGES: IN NO EVENT, REGARDLESS OF THE FORM OF THE CLAIM OR CAUSE OF ACTION (WHETHER BASED IN CONTRACT, INFRINGEMENT, NEGLIGENCE, STRICT LIABILITY, OTHER TORT, OR OTHERWISE), SHALL ALBÉR'S LIABILITY TO YOU EXCEED THE PRICE PAID BY YOU FOR THE SOFTWARE. YOU AGREE THAT ALBÉR'S LIABILITY TO YOU SHALL NOT EXTEND TO INCLUDE SPECIAL, INCIDENTAL, CONSEQUENTIAL, OR PUNITIVE DAMAGES EVEN IF ALBÉR IS ADVISED OF THE POSSIBILITY OF THESE DAMAGES. The term "consequential damages" shall include, but not be limited to, loss of anticipated profits, business interruption, loss of use, revenue, reputation and data, costs incurred, including without limitation, for capital, fuel, power and loss or damage to property or equipment. You acknowledge that this Agreement reflects this allocation of risk.

COPYRIGHT: This Software is the proprietary property of Albér and/or its suppliers and is protected by United States copyright laws, other applicable copyright laws, and international treaty provisions. Title and ownership of all copyrights to the Software remain in Albér or third parties. Accordingly, your rights to use, copy and modify the Software are strictly limited to the specific rights provided in this Agreement or as may otherwise be required by applicable copyright law.

U.S. GOVERNMENT RESTRICTED RIGHTS: This Software is developed at private expense and is provided with "Restricted Rights." Use, duplication, or disclosure by the United States Government is subject to restrictions set forth in the Federal Acquisition Regulations and its Supplements.

ASSIGNMENT: You may not sublicense, assign, or otherwise transfer this license of the Software without the prior written consent of Albér. Any such transfer of rights, duties, or obligations is void and terminates this Agreement.

EXPORT RESTRICTIONS: You may not export the Software in violation of applicable export laws and regulations of the applicable countries. You agree to comply with all laws, regulations, decrees and orders of the United States of America that restrict the exportation (or re-exportation) of the Software to other countries, including, without limitation, the U.S. Export Administration Regulations.

UPDATE POLICY: Albér may create, from time to time, updated versions of the Software. Albér reserves the right to make changes to or improvements in any aspect of the Software at any time without prior notice to you and without an obligation to supply such changed and/or improved Software to you.

NUCLEAR/MEDICAL: THE SOFTWARE IS NOT FOR USE IN CONNECTION WITH ANY NUCLEAR, MEDICAL, LIFE-SUPPORT, AND RELATED APPLICATIONS. You agree to defend, indemnify, and hold harmless Albér from any claims, losses, suits, judgments and damages, including incidental and consequential damages, arising from such use, whether the cause of action be based in tort, contract or otherwise, including allegations that the Albér's liability is based on negligence or strict liability.

JAVA SUPPORT: The Software may contain support for programs written in Java. Java Technology is not fault tolerant and is not designed, manufactured, or intended for use or resale as online control equipment in hazardous environments requiring fail-safe performance, such as in the operation of nuclear

facilities, aircraft navigation or communication systems, air traffic control, direct life support machines, or weapons systems, in which the failure of java technology could lead directly to death, personal injury, or severe physical or environmental damage.

COMPLETE AGREEMENT/GOVERNING LAW/VENUE: This Software license agreement comprises the final and complete agreement between the parties. No person is authorized to change or modify this Agreement except an executive officer of Albér Corporation and then only in writing. The laws of the United States and the State of Florida shall apply to this Agreement and its interpretation without reference to choice or conflict of laws principles. Albér and you hereby irrevocably submit to the personal and subject matter jurisdiction of any State of Florida or federal court sitting in Miami, Florida, in any action or proceeding arising from or relating to this Agreement. If any provision of this Agreement is held to be void, invalid, unenforceable, or illegal, the other provisions shall continue in full force and effect.

LIMITED WARRANTY FOR ALBÉR PRODUCTS

This Warranty is given ONLY to purchasers who buy for commercial or industrial use in the ordinary course of each purchaser's business.

General:

Albér Corp. products and systems are, in our opinion, the finest available. We take pride in our products and are pleased that you have chosen them. Under certain circumstances, we offer with our products the following One Year Warranty against Defects in Material and Workmanship.

Please read your Warranty carefully. This Warranty sets forth our responsibilities in the unlikely event of defect and tells you how to obtain performance under this Warranty.

ONE YEAR LIMITED WARRANTY AGAINST DEFECTS IN MATERIAL AND WORKMANSHIP

ALBÉR PRODUCTS COVERED:

BDS-40, BDS 256XL, BDSU, MPM-100, UXIM and UXTM.

Terms of Warranty:

As provided herein, the Albér product is warranted to be free of defects in material and workmanship for a period of twelve (12) months from date of commissioning, not to exceed eighteen (18) months from date of shipment, provided that startup is performed by Albér authorized personnel, and the product has been stored in a suitable environment prior to start-up. The start-up date will be determined only from the completed ASCOMP file provided to Albér from User and accepted by Albér. The product shipment date will be determined only from the Albér bill of lading. If any part or portion of the Albér product fails to conform to the Warranty within the Warranty period, Albér, at its option, will furnish new or factory remanufactured products for repair or replacement of that portion or part.

Warranty Extends to First Purchaser for Use. Non-transferable:

This Warranty is extended to the first person, firm, association or corporation for whom the Albér product specified herein is originally installed for use (the "User"). This Warranty is not transferable or assignable without the prior written permission of Albér.

Assignment of Warranties:

Albér assigns to User any warranties which are made by manufacturers and suppliers of components of, or accessories to, the Albér product and which are assignable, but Albér makes NO REPRESENTATIONS as to the effectiveness or extent of such warranties, assumes NO RESPONSIBILITY for any matters which may be warranted by such manufacturers or suppliers and extends no coverage under this Warranty to such components or accessories.

Drawings. Descriptions:

Albér warrants for the period and on the terms of the Warranty set forth herein that the Albér product will conform to the descriptions contained in the approved drawings, if any, applicable thereto, to Albér's final invoices, and to applicable Albér product brochures and manuals current as of the date of product shipment ("Descriptions"). Albér does not control the use of any Albér product. Accordingly, it is understood that the Descriptions are NOT WARRANTIES OF PERFORMANCE and NOT WARRANTIES OF FITNESS FOR A PARTICULAR PURPOSE.

Warranty Claims Procedure:

Within a reasonable time, but in no case to exceed thirty (30) days after User's discovery of a defect, User shall contact Albér at 1-800-851-4632.

User shall ship the product, with proof of purchase, to Albér freight prepaid. Albér products shipped to Albér without a return authorization number will be refused and returned freight collect to User at User's expense. Products shipped by User to Albér which have incurred freight damage due to User's improper packaging of the product will not be covered by this Warranty and any replacement parts, components or products needed will be invoiced in the full current price amount and returned freight collect to User.

Subject to the limitations specified herein, Albér will replace, without charge for Albér labor or materials, subsequent to its inspection, and return freight prepaid F.O.B. Albér's facility, the product shipped to Albér with a return authorization number and warranted hereunder which does not conform to this Warranty.

Warranty coverage will be applicable only after Albér's inspection discloses the claimed defect and shows no signs of treatment or use that would void the coverage of this Warranty. All defective products and component parts replaced under this warranty become the property of Albér.

Warranty Performance of Component Manufacturers:

It is Albér's practice, consistent with its desire to remedy Warranty defects in the most prompt and effective manner possible, to cooperate with and utilize the services of component manufacturers and their authorized representatives in the performance of work to correct defects in the product components. Accordingly, Albér may utilize third parties in the performance of Warranty work, including repair or replacement hereunder, where, in Albér's opinion, such work can be performed in less time, with less expense, or in closer proximity to the Albér product.

Items Not Covered By Warranty:

THIS WARRANTY DOES NOT COVER DAMAGE OR DEFECT CAUSED BY misuse, improper application, wrong or inadequate electrical current or connection, negligence, inappropriate on site operating conditions, repair by non-Albér designated personnel, accident in transit, tampering, alterations, a change in location or operating use, exposure to the elements, Acts of God, theft or installation contrary to Albér's recommendations or specifications, or in any event if the Albér serial number has been altered, defaced, or removed.

THIS WARRANTY DOES NOT COVER shipping costs, installation costs, or maintenance or service items and further, except as may be provided herein, does NOT include labor costs or transportation charges arising from the replacement of the Albér product or any part thereof or charges to remove or reinstall same at any premises of User.

REPAIR OR REPLACEMENT OF A DEFECTIVE PRODUCT OR PART THEREOF DOES NOT EXTEND THE ORIGINAL WARRANTY PERIOD.

Limitations:

- THIS WARRANTY IS IN LIEU OF AND EXCLUDES ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.
- USER'S SOLE AND EXCLUSIVE REMEDY IS REPAIR OR REPLACEMENT OF THE ALBÉR PRODUCT AS SET FORTH HEREIN.
- IF USER'S REMEDY IS DEEMED TO FAIL OF ITS ESSENTIAL PURPOSE BY A COURT OF COMPETENT JURISDICTION, ALBÉR'S RESPONSIBILITY FOR PROPERTY LOSS OR DAMAGE SHALL NOT EXCEED THE NET PRODUCT PURCHASE PRICE.
- IN NO EVENT SHALL ALBÉR ASSUME ANY LIABILITY FOR INDIRECT, SPECIAL, INCIDENTAL, CONSEQUENTIAL OR EXEMPLARY DAMAGES OF ANY KIND WHATSOEVER, INCLUDING WITHOUT LIMITATION LOST PROFITS, BUSINESS INTERRUPTION OR LOSS OF DATA, WHETHER ANY CLAIM IS BASED UPON THEORIES OF CONTRACT, NEGLIGENCE, STRICT LIABILITY, TORT, OR OTHERWISE.

Miscellaneous:

- NO SALESPERSON, EMPLOYEE OR AGENT OF ALBÉR IS AUTHORIZED TO ADD TO OR VARY THE TERMS OF THIS WARRANTY. Warranty terms may be modified, if at all, only by a writing signed by a Albér officer.
- Albér obligations under this Warranty are conditioned upon Albér timely receipt of full payment of the product purchase price and any other amounts due. During the period when any amounts are overdue from User, Albér warranty obligations shall be suspended. The warranty expiration date shall not be extended upon payment of the overdue amount. Albér reserves the right to supplement or change the terms of this Warranty in any subsequent warranty offering to User or others.
- In the event that any provision of this Warranty should be or becomes invalid and/or unenforceable during the warranty period, the remaining terms and provisions shall continue in full force and effect.
- This Warranty shall be governed by, and construed under, the laws of the State of Florida, without reference to the conflict of laws principles thereof.
- This Warranty represents the entire agreement between Albér and User with respect to the subject matter herein and supersedes all prior or contemporaneous oral or written communications, representations, understandings or agreements relating to this subject.

Table of Contents

1	Modbus™ Protocol (ASCII Frame)	10
2	UXIM/UXTM Register List for Function 3, 4 and 16 Data Address: 0000H – 270EH.....	11
2.1	Cell Parameters	11
2.2	String Parameters	12
2.3	Status Registers.....	13
2.4	Event Details	17
2.5	Configuration	19
2.6	Unit Information	29
3	Using the Commands.....	29
3.1	Data Transformation	29
3.2	System Configurations	31
4	Alarm Type and PCB Revision/Version Format Appendix.....	33
4.1	Alarm Type Format	33
4.2	PCB version/revision format	34

1 Modbus™ Protocol (ASCII Frame)

This section describes the details of the frame, ASCII character, address, error control, bits per byte, and baud rate settings.

Frame:	Colon, Address (H), Address (L), Function (H), Function (L), Data, LRC (H), LRC (L), CR, LF
ASCII Character:	Every field in the frame is sent in ASCII character.
Address:	Device address is defined as: UXTM: 1-254 UXIM: 1-254
Error Control:	LRC If correct, send requested data back; if error is found, do nothing. The following binary bytes in the frame are checked: <ul style="list-style-type: none">• Address• Function• Data
Bits per Byte:	1 start bit, 7 data bits, 2 stop bits, no parity
Baud Rate:	1200 bps, 2400 bps, 4800 bps, 9600 bps, 19200 bps

2 UXIM/UXTM Register List for Function 3, 4 and 16

Data Address: 0000H – 270EH

This section describes the details of the cell parameters, string parameters, status registers, event details, configuration, and unit information.

2.1 Cell Parameters

This section describes the details of the cell voltage, cell temperature, cell resistance, and intercell resistance settings. For information on string parameters, refer to section 2.2. For additional information on Alarm type formats refer to section 4.1.

Category	Name/Description	Reference	Data Address
Cell Voltage	Cell Voltage 1	33586	0E01H
	Cell Voltage 2		

	Cell Voltage 256	33841	0F00H
Cell Temperature	Cell Temperature 1	33906	0F41H
	Cell Temperature 2		

	Cell Temperature 256	34161	1040H
Resistance Test Start Time (For both Cell resistance and Intercell)	Year/Month	34543	11BEH
	Day/Hour	34544	11BFH
	Minute/Second	34545	11C0H
Cell Resistance	Cell Resistance 1	34546	11C1H
	Cell Resistance 2		

	Cell Resistance 256	34801	12C0H
Intercell Resistance	Intercell 1	34866	1301H
	Intercell 2		

	Intercell 256	35121	1400H
Charger Cable Resistance*	Positive Charger Cable Resistance	39242	2419H
	Negative Charger Cable Resistance	39243	241AH
Ground Fault Current	GF Current Cell 1	39244	241BH
	GF Current Cell 2		

	GF Current Cell 256	39499	251AH
Baseline Internal Resistance	Cell Resistance 1	39711	25EEH
	Cell Resistance 2		

	Cell Resistance 256	39966	26EDH
Baseline Intercell Resistance	Intercell 1	35122	1401H
	Intercell 2	35123	1402H

	Intercell 255	35375	14FEH

*UXIM only

2.2 String Parameters

This section describes the details of the overall voltage, string current, ripple, ambient temperature and digital input settings. For information on status registers, refer to section 2.3. For additional information on Alarm type formats refer to section 4.1.

Category	Name/Description	Reference	Data Address
Overall Voltage	OV String 1	32050	0801H
	OV String 2		
	OV String 3		
	OV String 4		

	OV String 16	32065	0810H
String Current (MSB = sign bit; 0 = Positive, 1 = Negative)	String 1 Current	32082	0821H
	String 2 Current		
	String 3 Current		
	String 4 Current		

	String 16 Current	32097	0830H
Float Current	String 1 Float Current	32114	0841H
	...		
	String 16 Float Current	32129	0850H
Ripple	String 1 Ripple	32146	0861H
	String 2 Ripple		
	String 3 Ripple		
	String 4 Ripple		

	String 16 Ripple	32161	0870H
Ambient Temperature	Ambient Temperature 1	31922	0781H
	*Ambient Temperature 2	31923	0782H
Ground Fault Resistance*	Ground Fault Resistance at Battery System Positive	39707 39708	25EAH 25EBH
	Ground Fault Resistance at Battery System Negative	39709 39710	25ECH 25EDH
	Digital Inputs (<i>Bitfield</i>)	39500	251BH
	DI-1	BIT 0	
	DI-2	BIT 1	
	DI-3	BIT 2	
	(Reserved)	BITS 3 - 15	

*UXIM only

2.3 Status Registers

This section describes the details of the status; page register and alarm disable timer settings. For information on event details, refer to section 2.4. For additional information on Alarm type formats refer to section 4.1.

Category	Name/Description		Reference	Data Address
Status	System Status		30385	0180H
	Mode	Bit State	Bit	
	Monitor Mode	1 = Monitor Mode	BIT 0	
	R-Test in progress	1 = R-Test in progress	BIT 1	
	Discharge in progress	1 = Discharge in progress	BIT 2	
	Calibration in progress	1 = Calibration in progress	BIT 3	
	Diagnostic in progress	1 = Diagnostic in progress	BIT 4	
	Maintenance mode	1 = Maintenance mode	BIT 5	
	Major Alarm in progress	1 = Alarm in progress	BIT 6	
	Hardware Failure	1 = Hardware Failure	BIT 7	
	Alarm Acknowledged	1 = Alarm Acknowledged	BIT 8	
	Minor Alarm In Progress	1 = Alarm in progress	BIT 9	
	Reserved	Reserved	BIT 10-15	
	String Status		30386	0181H
	Parameter	Bit State	Bit	
	String 1 Discharge State	1 = Discharge in progress	BIT 0	
	String 2 Discharge State	1 = Discharge in progress	BIT 1	
	String 3 Discharge State	1 = Discharge in progress	BIT 2	
	String 4 Discharge State	1 = Discharge in progress	BIT 3	
			30387	0182H
	String 1 Alarm Status	1 = String in alarm	BIT 0	
	String 2 Alarm Status	1 = String in alarm	BIT 1	
	String 3 Alarm Status	1 = String in alarm	BIT 2	
	String 4 Alarm Status	1 = String in alarm	BIT 3	
	Major High Alarm Status		39027	2342H
	Parameter	Bit State	Bit	
	Cell Voltage	1 = Alarm in progress	BIT 0	
	String Voltage	1 = Alarm in progress	BIT 1	
	Float Current	1 = Alarm in progress	BIT 2	
	Ripple Current	1 = Alarm in progress	BIT 3	
	Cell Temperature	1 = Alarm in progress	BIT 4	
	Cell Resistance	1 = Alarm in progress	BIT 5	
	Intercell	1 = Alarm in progress	BIT 6	
	Discharge Current	1 = Alarm in progress	BIT 7	

Status Registers (Continued)

Category	Name/Description		Reference	Data Address
	Charger Cable	1 = Alarm in progress	BIT 8	
	Digital Input	1 = Alarm in progress	BIT 9	
	Reserved	1 = Alarm in progress	BIT 10	
	Ambient Temperature	1 = Alarm in progress	BIT 11	
	Intertier	1 = Alarm in progress	BIT 12	
	Cell to Ambient	1 = Alarm in progress	BIT 13	
	Thermal runaway cell to ambient	1 = Alarm in progress	BIT 14	
	Thermal runaway float current	1 = Alarm in progress	BIT 15	
	Major Low Alarm Status		39028	2343H
	Parameter	Bit State	Bit	
	Cell Voltage	1 = Alarm in progress	BIT 0	
	String Voltage	1 = Alarm in progress	BIT1	
	Float Current	1 = Alarm in progress	BIT 2	
	Ripple Current	1 = Alarm in progress	BIT 3	
	Cell Temperature	1 = Alarm in progress	BIT 4	
	Cell Resistance	1 = Alarm in progress	BIT 5	
	Reserved	1 = Alarm in progress	BIT 6	
	Reserved	1 = Alarm in progress	BIT 7	
	Reserved	1 = Alarm in progress	BIT 8	
	Digital Input	1 = Alarm in progress	BIT 9	
	Ground Fault	1 = Alarm in progress	BIT 10	
	Ambient Temperature	1 = Alarm in progress	BIT 11	
	Intertier	1 = Alarm in progress	BIT 12	
	Reserved	1 = Alarm in progress	BIT 13 – BIT 15	
	Minor High Alarm Status		39029	2344H
	Parameter	Bit State	Bit	
	Cell Voltage	1 = Alarm in progress	BIT 0	
	String Voltage	1 = Alarm in progress	BIT1	
	Float Current	1 = Alarm in progress	BIT 2	
	Ripple Current	1 = Alarm in progress	BIT 3	
	Cell Temperature	1 = Alarm in progress	BIT 4	
	Cell Resistance	1 = Alarm in progress	BIT 5	
	Intercell	1 = Alarm in progress	BIT 6	
	Discharge Current	1 = Alarm in progress	BIT 7	
	Charger Cable	1 = Alarm in progress	BIT 8	
	Digital Input	1 = Alarm in progress	BIT 9	

Status Registers (Continued)

Category	Name/Description		Reference	Data Address
	Reserved	1 = Alarm in progress	BIT 10	
	Ambient Temperature	1 = Alarm in progress	BIT 11	
	Intertier	1 = Alarm in progress	BIT 12	
	Cell to Ambient	1 = Alarm in progress	BIT 13	
	Thermal runaway cell to ambient	1 = Alarm in progress	BIT 14	
	Thermal runaway float current	1 = Alarm in progress	BIT 15	
	Minor Low Alarm Status		39030	2345H
	Parameter	Bit State	Bit	
	Minor Low Alarm	1 = Alarm in progress	BIT 0	
	String Voltage	1 = Alarm in progress	BIT 1	
	Float Current	1 = Alarm in progress	BIT 2	
	Ripple Current	1 = Alarm in progress	BIT 3	
	Cell Temperature	1 = Alarm in progress	BIT 4	
	Cell Resistance	1 = Alarm in progress	BIT 5	
	Reserved	1 = Alarm in progress	BIT 6	
	Reserved	1 = Alarm in progress	BIT 7	
	Reserved	1 = Alarm in progress	BIT 8	
	Digital Input	1 = Alarm in progress	BIT 9	
	Ground Fault	1 = Alarm in progress	BIT 10	
	Ambient Temperature	1 = Alarm in progress	BIT 11	
	Intertier	1 = Alarm in progress	BIT 12	
	Reserved	1 = Alarm in progress	BIT 13 – BIT 15	
Page Registers	Discharge Page Register	Current page of discharge data. Data is accessed one page at a time, 10 records per page starting with page 0.	49501	251CH
	Alarm Page Register	Current page of alarm data. Data is accessed one page at a time, 10 records per page starting with page 0.	49502	251DH

Status Registers (Continued)

Category	Name/Description		Reference	Data Address
Alarm Disable Timer	Discharge Remaining Time of Alarm Disable/Discharge Duration Note: While a discharge is in progress this register keeps track of its duration in seconds. At the end of a discharge the register holds the alarm disable time (discharge normalization time) remaining in seconds.	Byte 1/Byte 2	39503	251EH
		Byte 3/Byte 4	39504	251FH
	R-Test Remaining Time of Alarm Disable	Byte 1/Byte 2	39673	25C8H
		Byte 3/Byte 4	39674	25C9H

2.4 Event Details

This section describes the details of alarms, discharge data and resistance test date/time events. For information on the configuration, refer to section 2.5. For additional information on Alarm type formats refer to section 4.1.

Category	Name/Description	Reference	Data Address
Major Alarms <i>(One page of 1 to 10 records each time. OFFH is stuffed in all remaining memory spaces After the last record)</i>	Actual Alarm number = 10 x Page number + Record number		
	Alarm Type of record 1 (See section 4.1 for Alarm type formats.)	39505	2520H
	Current Level of record 1		
	Starting Year/Month of record 1		
	Starting Day/Hour of record 1		
	Starting Minute/Second of record 1		
	...		
	Alarm Type of record 10 (See section 4.1 for Alarm type formats.)		
	Current Level of record 10		
	Starting Year/Month of record 10		
	Starting Day/Hour of record 10		
	Starting Minute/Second of record 10		
	...		
		39559	2556H
Category	Name/Description	Reference	Data Address
Minor Alarms <i>(One page of 1 to 10 records each time. OFFH is stuffed in all remaining memory spaces After the last record)</i>	Actual Alarm number = 10 x Page number + Record number		
	Alarm Type of record 1 (See section 4.1 for Alarm type formats.)	39043	9882H
	Current Level of record 1		
	Starting Year/Month of record 1		
	Starting Day/Hour of record 1		
	Starting Minute/Second of record 1		
	...		
	Alarm Type of record 10 (See section 4.1 for Alarm type formats.)		
	Current Level of record 10		
	Starting Year/Month of record 10		
	Starting Day/Hour of record 10		
	Starting Minute/Second of record 10		
	...		
		39097	2388H

Event Details (Continued)

Category	Name/Description	Reference	Data Address
Discharge Data <i>(One page of 1 to 10 records each time. OFFH is stuffed in all remaining memory spaces After the last record)</i>	Actual Discharge number = 10 x Page number + Record number		
	String Number of Record 1	39560	2557H
	Lowest OV of Record 1		
	Highest String Current of Record 1		
	Ambient Temperature at End of Record 1		
	Starting Year/Month of Record 1		
	Starting Day/Hour of Record 1		
	Starting Minute/Second of Record 1		
	Ending Year/Month of Record 1
	Ending Day/Hour of Record 1		
	Ending Minute/Second of Record 1		
	...		
	String Number of Record 10		
	Lowest OV of Record 10		
	Highest String Current of Record 10		
	Ambient Temperature at End of Record 10		
	Starting Year/Month of Record 10		
	Starting Day/Hour of Record 10
	Starting Minute/Second of Record 10		
	Ending Year/Month of Record 10		
	Ending Day/Hour of Record 10		
	Ending Minute/Second of Record 10		
	...		
		39669	25C4H
Resistance Test Date/Time	Resistance Test Year/Month	39670	25C5H
	Resistance Test Day/Hour	39671	25C6H
	Resistance Test Minute/Second	39672	25C7H

2.5 Configuration

This section describes the details of the thresholds, resistance test interval, firmware commands, site information, and remote password settings. For information on unit information details, refer to section 2.4. For additional information on Alarm type formats refer to section 4.1.

Category	Name/Description	Reference	Data Address
Major Alarm Thresholds (Segmented array) Not recommend for new integration	High Cell Voltage Alarm Threshold	42754	0AC1H
	Low Cell Voltage Alarm Threshold	42722	0AA1H
	High Cell Resistance Alarm Threshold	42946	0B81H
	Low Cell Resistance Alarm Threshold	42914	0B61H
	High intercell Resistance Alarm Threshold	42978	0BA1H
	High Cell Temperature Alarm Threshold	42850	0B21H
	Low Cell Temperature Alarm Threshold	42786	0AE1H
	High Ambient Temperature Alarm Threshold	42466	09A1H
	Low Ambient Temperature Alarm Threshold	42402	0961H
	High Overall Voltage Alarm Threshold	42562	0A01H
	Low Overall Voltage Alarm Threshold	42530	09E1H
	High String Current Alarm Threshold	42594	0A21H
	High Ripple Current Alarm Threshold	42690	0A81H
	High Float Current Alarm Threshold	42658	0A61H
	Low Float Current Alarm Threshold	42626	0A41H
	Cell to Ambient Temperature Deviation Threshold	43106	0C21H
	Cell to Ambient Thermal Runaway Threshold	49711	25EEH
	High Float Current Thermal Runaway Threshold	49712	25EFH
	Discharge Trigger Current Threshold (Not for Alarm, used for discharge detection)	49713	25F0H
	Ground Fault Resistance Positive Threshold (K Ω)*	49705	25E8H
	Ground Fault Resistance Negative Threshold (K Ω)*	49706	25E9H
	Ground Fault Current Threshold (future)	49714	25F1H
	High Positive Charger Cable Resistance Alarm Threshold*	49720	25F7H
	High Negative Charger Cable Resistance Alarm Threshold*	49721	25F8H
	High Intertier Resistance Threshold 1	43010	0BC1H
	High Intertier Resistance Threshold 2	43011	0BC2H
	High Intertier Resistance Threshold 3	43012	0BC3H
	High Intertier Resistance Threshold 4	43013	0BC4H
Major Alarm Thresholds (Sequential array) Only available in UXIM - 1.4.0 UXTM - 1.22.0 and after	High Cell Voltage Alarm Threshold	49134	23ADH
	Low Cell Voltage Alarm Threshold	49135	23AEH
	High Cell Resistance Alarm Threshold	49136	23AFH
	Low Cell Resistance Alarm Threshold	49137	23B0H
	High intercell Resistance Alarm Threshold	49138	23B1H
	High Cell Temperature Alarm Threshold	49139	23B2H
	Low Cell Temperature Alarm Threshold	49140	23B3H
	High Ambient Temperature Alarm Threshold	49141	23B4H
	Low Ambient Temperature Alarm Threshold	49142	23B5H

Configuration (Continued)

Category	Name/Description	Reference	Data Address
	High Overall Voltage Alarm Threshold	49143	23B6H
	Low Overall Voltage Alarm Threshold	49144	23B7H
	High String Current Alarm Threshold	49145	23B8H
	High Ripple Current Alarm Threshold	49146	23B9H
	High Float Current Alarm Threshold	49147	23BAH
	Low Float Current Alarm Threshold	49148	23BBH
	Cell to Ambient Temperature Deviation Threshold	49149	23BCH
	Cell to Ambient Thermal Runaway Threshold	49150	23BDH
	High Float Current Thermal Runaway Threshold	49151	23BEH
	Discharge Trigger Current Threshold (Not for Alarm, used for discharge detection)	49152	23BFH
	Ground Fault Resistance Positive Threshold (K Ω)*	49153	23C0H
	Ground Fault Resistance Negative Threshold (K Ω)*	49154	23C1H
	Ground Fault Current Threshold (future)	49155	23C2H
	High Positive Charger Cable Resistance Alarm Threshold*	49156	23C3H
	High Negative Charger Cable Resistance Alarm Threshold*	49157	23C4H
	High Intertier Resistance Threshold 1	49158	23C5H
	High Intertier Resistance Threshold 2	49159	23C6H
	High Intertier Resistance Threshold 3	49160	23C7H
	High Intertier Resistance Threshold 4	49161	23C8H
Minor Alarm Thresholds	High Cell Voltage Alarm Threshold	49027	2342H
	Low Cell Voltage Alarm Threshold	49028	2343H
	High Cell Resistance Alarm Threshold	49029	2344H
	Low Cell Resistance Alarm Threshold	49030	2345H
	High intercell Resistance Alarm Threshold	49031	2346H
	High Cell Temperature Alarm Threshold	49032	2347H
	Low Cell Temperature Alarm Threshold	49033	2348H
	High Ambient Temperature Alarm Threshold	49034	2349H
	Low Ambient Temperature Alarm Threshold	49035	234AH
	High Overall Voltage Alarm Threshold	49036	234BH
	Low Overall Voltage Alarm Threshold	49037	234CH
	High String Current Alarm Threshold	49038	234DH
	High Ripple Current Alarm Threshold	49039	234EH
	High Float Current Alarm Threshold	49040	234FH
	Low Float Current Alarm Threshold	49041	2350H
	Cell to Ambient Temperature Deviation Threshold	49042	2351H
	Cell to Ambient Thermal Runaway Threshold	49043	2352H
	High Float Current Thermal Runaway Threshold	49044	2353H
	Ground Fault Resistance Positive Threshold (K Ω)*	49045	2354H

Configuration (Continued)

Category	Name/Description		Reference	Data Address
	Ground Fault Resistance Negative Threshold (K Ω)*		49046	2355H
	Ground Fault Current Threshold (future)		49047	2356H
	High Positive Charger Cable Resistance Alarm Threshold*		49048	2357H
	High Negative Charger Cable Resistance Alarm Threshold*		49049	2358H
	High Intertier Resistance Threshold 1		49050	2359H
	High Intertier Resistance Threshold 2		49051	235AH
	High Intertier Resistance Threshold 3		49052	235BH
	High Intertier Resistance Threshold 4		49053	235CH
Intertier Configuration	Intertier 1 Configuration	String # (Byte 1)	49715	25F2H
		Cell # (Byte 2)		
	Intertier 2 Configuration	String # (Byte 1)	49716	25F3H
		Cell # (Byte 2)		
	Intertier 3 Configuration	String # (Byte 1)	49717	25F4H
		Cell # (Byte 2)		
	Intertier 4 Configuration	String # (Byte 1)	49718	25F5H
		Cell # (Byte 2)		
Enables	Ambient Temperature Enable (A value of 0 means all ambient temperature sensors disabled. A value of N means Ambient Temperatures 1 to N are enabled.)		49719	25F6H
Resistance Test Interval	Resistance Test Period (Days)		49694	25DDH
Resistance Alarm Type	BIT0 = 1 Check resistance and intercell alarm using percentage change. = 0 Check resistance and intercell alarm using absolute value.		49062	2365H
Major High Alarm Enable	BIT0 = 1 Enable Cell Voltage BIT1 = 1 Enable String Voltage BIT2 = 1 Enable Float Current BIT3 = 1 Enable Ripple Current BIT4 = 1 Enable Cell Temperature BIT5 = 1 Enable Cell Resistance BIT6 = 1 Enable Intercell BIT7 = 1 Enable Discharge Current BIT8 = 1 Enable Charger Cable Resistance BIT9 = 1 Enable Digital Input BIT10: Reserved BIT11=1 Enable Ambient Temperature BIT12=1 Enable Intertier BIT13=1 Enable Cell to Ambient BIT14=1 Enable Thermal Runaway Cell to Ambient BIT15=1 Enable Thermal Runaway Float current		49063	2366H

Configuration (Continued)

Category	Name/Description	Reference	Data Address
Major Low Alarm Enable	BIT0 = 1 Enable Cell Voltage BIT1 = 1 Enable String Voltage BIT2 = 1 Enable Float Current BIT3 = 1 Enable Ripple Current BIT4 = 1 Enable Cell Temperature BIT5 = 1 Enable Cell Resistance BIT6: Reserved BIT7: Reserved BIT8: Reserved BIT9: Enable Digital Input BIT10 = 1 Enable Ground Fault BIT11=1 Enable Ambient Temperature BIT12=1 Enable Intertier BIT13–BIT15: Reserved	49064	2367H
Minor High Alarm Enable	BIT0 = 1 Enable Cell Voltage BIT1 = 1 Enable String Voltage BIT2 = 1 Enable Float Current BIT3 = 1 Enable Ripple Current BIT4 = 1 Enable Cell Temperature BIT5 = 1 Enable Cell Resistance BIT6 = 1 Enable Intercell BIT7 = 1 Enable Discharge Current BIT8 = 1 Enable Charger Cable Resistance BIT9 = 1 Enable Digital Input BIT10: Reserved BIT11=1 Enable Ambient Temperature BIT12=1 Enable Intertier BIT13=1 Enable Cell to Ambient BIT14=1 Enable Thermal Runaway Cell to Ambient BIT15=1 Enable Thermal Runaway Float current	49065	2368H

Configuration (Continued)

Category	Name/Description	Reference	Data Address
Minor Low Alarm Enable	BIT0 = 1 Enable Cell Voltage BIT1 = 1 Enable String Voltage BIT2 = 1 Enable Float Current BIT3 = 1 Enable Ripple Current BIT4 = 1 Enable Cell Temperature BIT5 = 1 Enable Cell Resistance BIT6: Reserved BIT7: Reserved BIT8: Reserved BIT9 = 1 Enable Digital Input BIT10 = 1 Enable Ground Fault BIT11=1 Enable Ambient Temperature BIT12=1 Enable Intertier BIT13–BIT15: Reserved	49066	2369H
Major High Alarm Latch	BIT0 = 1 Latch Cell Voltage BIT1 = 1 Latch String Voltage BIT2 = 1 Latch Float Current BIT3 = 1 Latch Ripple Current BIT4 = 1 Latch Cell Temperature BIT5 = 1 Latch Cell Resistance BIT6 = 1 Latch Intercell BIT7 = 1 Latch Discharge Current BIT8 = 1 Latch Charger Cable Resistance BIT9 = 1 Latch Digital Input BIT10: Reserved BIT11=1 Latch Ambient Temperature BIT12=1 Latch Intertier BIT13=1 Enable Cell to Ambient BIT14=1 Enable Thermal Runaway Cell to Ambient BIT15=1 Enable Thermal Runaway Float current	49067	236AH

Configuration (Continued)

Category	Name/Description	Reference	Data Address
Major Low Alarm Latch	BIT0 = 1 Latch Cell Voltage BIT1 = 1 Latch String Voltage BIT2 = 1 Latch Float Current BIT3 = 1 Latch Ripple Current BIT4 = 1 Latch Cell Temperature BIT5 = 1 Latch Cell Resistance BIT6: Reserved BIT7: Reserved BIT8: Reserved BIT9: Latch Digital Input BIT10 = 1 Latch Ground Fault BIT11=1 Latch Ambient Temperature BIT12=1 Latch Intertier BIT13–BIT15: Reserved	49068	236BH
Minor High Alarm Latch	BIT0 = 1 Latch Cell Voltage BIT1 = 1 Latch String Voltage BIT2 = 1 Latch Float Current BIT3 = 1 Latch Ripple Current BIT4 = 1 Latch Cell Temperature BIT5 = 1 Latch Cell Resistance BIT6 = 1 Latch Intercell BIT7 = 1 Latch Discharge Current BIT8 = 1 Latch Charger Cable Resistance BIT9 = 1 Latch Digital Input BIT10: Reserved BIT11=1 Latch Ambient Temperature BIT12=1 Latch Intertier BIT13=1 Enable Cell to Ambient BIT14=1 Enable Thermal Runaway Cell to Ambient BIT15=1 Enable Thermal Runaway Float current	49069	236CH

Configuration (Continued)

Category	Name/Description	Reference	Data Address
Minor Low Alarm Latch	BIT0 = 1 Latch Cell Voltage BIT1 = 1 Latch String Voltage BIT2 = 1 Latch Float Current BIT3 = 1 Latch Ripple Current BIT4 = 1 Latch Cell Temperature BIT5 = 1 Latch Cell Resistance BIT6: Reserved BIT7: Reserved BIT8: Reserved BIT9 = 1 Latch Digital Input BIT10 = 1 Latch Ground Fault BIT11=1 Latch Ambient Temperature BIT12=1 Latch Intertier BIT13–BIT15: Reserved	49070	236DH

*UXIM only

Configuration (Continued)

Category	Name/Description		Reference	Data Address
Firmware Commands	Firmware Control Register		43490	0DA1H
	Function	Value		
	Start Resistance Test	0000H		
	Stop Resistance Test	0001H		
	Alarm Reset	0002H		
	Delete Discharge Data	0003H		
	Alarm Acknowledge	0004H		
Site Information (Null terminated strings or maximum length)	Location Name	Byte 1/Byte 2	49673	25C8H

	Location Name	Byte 19/Byte 20	49682	25D1H
	Battery Name	Byte 1/Byte 2	40386	0181H

	Battery Name	Byte 41/Byte 42	40406	0195H
	String Name1	Byte 1/Byte 2	41250	04E1H

	String Name1	Byte 41/Byte 42	41270	04F5H
	String Name2	Byte 1/Byte 2	41271	04F6H
	
	String Name2	Byte 41/Byte 42	41291	050AH
	String Name3	Byte 1/Byte 2	41292	050BH
	
	String Name3	Byte 41/Byte 42	41312	051FH
	String Name4	Byte 1/Byte 2	41313	0520H
	
	String Name4	Byte 41/Byte 42	41333	0534H
	String Name5	Byte 1/Byte 2	41334	0535H
	
	String Name5	Byte 41/Byte 42	41354	0549H
	String Name6	Byte 1/Byte 2	41355	054AH
	
	String Name6	Byte 41/Byte 42	41375	055EH
	String Name7	Byte 1/Byte 2	41376	055FH
	
	String Name7	Byte 41/Byte 42	41396	0573H
	String Name8	Byte 1/Byte 2	41397	0574H
	
	String Name8	Byte 41/Byte 42	41417	0588H
	String Name9	Byte 1/Byte 2	41418	0589H
	
	String Name9	Byte 41/Byte 42	41438	059DH
	String Name10	Byte 1/Byte 2	41439	059EH

Configuration (Continued)

Category	Name/Description		Reference	Data Address
	
	String Name10	Byte 41/Byte 42	41459	05B2H
	String Name11	Byte 1/Byte 2	41460	05B3H
	
	String Name12	Byte 41/Byte 42	41480	05C7H
Digital Input Alarm Configuration	Digital Input Major Alarm Latch <ul style="list-style-type: none"> D0 = 1 Latch Digital Input 1 D1 = 1 Latch Digital Input 2 D2 = 1 Latch Digital Input 3 D3 – D15: Reserved 		49082	2379H
	Digital Input Minor Alarm Latch <ul style="list-style-type: none"> D0 = 1 Latch Digital Input 1 D1 = 1 Latch Digital Input 2 D2 = 1 Latch Digital Input 3 D3 – D15: Reserved 		49083	237AH
	Digital Input Major Alarm Selection <ul style="list-style-type: none"> D0 = 1 Enable Digital Input 1 D1 = 1 Enable Digital Input 2 D2 = 1 Enable Digital Input 3 D3 – D15: Reserved 		49084	237BH
	Digital Input Minor Alarm Selection <ul style="list-style-type: none"> D0 = 1 Enable Digital Input 1 D1 = 1 Enable Digital Input 2 D2 = 1 Enable Digital Input 3 D3 – D15: Reserved 		49085	237CH

Configuration (Continued)

Category	Name/Description		Reference	Data Address
	Digital Input Open/Close 1: Normal Open 0: Normal Close • D0: Digital Input 1 • D1: Digital Input 2 • D2: Digital Input 3 • D3 – D15: Reserved		49086	237DH
Digital Input Name	Digital Input Name1	Byte 1/Byte 2	49087	237EH
	...			
	Digital Input Name1	Byte 19/Byte 20	49096	2387H
	Digital Input Name2	Byte 1/Byte 2	49097	2388H
	...			
	Digital Input Name2	Byte 19/Byte 20	49106	2391H
	Digital Input Name3	Byte 1/Byte 2	49107	2392H
	...			
	Digital Input Name3	Byte 19/Byte 20	49116	239BH
	String Name13	Byte 1/Byte 2	41481	05C8H
	
	String Name13	Byte 41/Byte 42	41501	05DCH
	String Name14	Byte 1/Byte 2	41502	05DDH
	
	String Name14	Byte 41/Byte 42	41522	05F1H
	String Name15	Byte 1/Byte 2	41523	05F2H
	
	String Name15	Byte 41/Byte 42	41543	0606H
	String Name16	Byte 1/Byte 2	41544	0607H
	
Remote Password (Null terminated or maximum length)	String Name16	Byte 41/Byte 42	41564	061BH
	Password 1	Byte 1/Byte 2	49683	25D2H
	Password 1	Byte 3/Byte 4	49684	25D3H
	Password 1	Byte 5/ Byte 6	49685	25D4H

2.6 Unit Information

This section describes the details of the unit settings. For additional information on PCB version/revision format refer to section 4.2.

Category	Name/Description	Reference	Data Address
Unit Settings	Model Number (ASCII)	39686	25D5
	
		39689	25D8
	Serial Number (ASCII)	39690	25D9
	
		39699	25E2
	Firmware Version (ASCII)	39700	25E3
	
		39703	25E6
	PCB Version (See section 4.2 for PCB version/revision format.)	39704	25E7
	Installation Date: Year/Day	43170	0C61H
	Install Date ____/Month	43171	0C62H
	System Configuration (Reference Section 3.2)	49690	25D9H
	System Time: Year/Month	49691	25DAH
	System Time: Day/Hour	49692	25DBH
	System Time: Minute/Second	49693	25DCH

3 Using the Commands

In the communication frames, only integer numbers can be transmitted. Transformation between integer numbers and decimal numbers is necessary when the computer receives and sends data.

3.1 Data Transformation

This section describes the details of the data transformation which is used for the following specific parameters.

Parameters	Transformation	
	Before Send	After Receive
Overall voltage (VDC)		/100
Cell voltage (VDC)		/1000
String current (A DC)		/1
Float current (mA DC)		/1
Ground Fault current (mA DC)		/1

Parameters	Transformation	
	Before Send	After Receive
Internal resistance ($\mu\Omega$)		/1
Intercell resistance ($\mu\Omega$)		/1
Ground Fault resistance (Ω)*		/1
Temperature (deg C)		/1024
Threshold of overall voltage (VDC)	X 100	/100
Threshold of cell voltage (VDC)	X 1000	/1000
Threshold of String current (A DC)	X 1	/1
Threshold of float current (mA DC)	X 1	/1
Threshold of internal resistance ($\mu\Omega$)	X 1	/1
Threshold of intercell resistance ($\mu\Omega$)	X 1	/1
Threshold of Ground Fault resistance ($K\Omega$)*	X 1	/1
Threshold of temperature (deg C)	X 1024	/1024
Discharge level in current mode (A DC)	X1	/1

*UXIM only

3.2 System Configurations

This section describes the details of the system configuration types.

Technology	Battery/String configuration (number of strings X number of data points X Nominal voltage of data point)	Configuration Number
1V – NiCad Cells (24V)	1X18X1V	0
2V Cells (24V)	1X12X2V	1
2V Cells (24V)	2X12X2V	2
2V Cells (48V)	1X24X2V	3
4V Mono-Blocks (24V)	1X6X4V	4
	2X6X4V	5
	3X6X4V	6
	4X6X4V	7
4V Mono-Blocks (48V)	1X12X4V	8
	2X12X4V	9
6V Mono-Blocks (24V)	1X4X6V	10
	2X4X6V	11
	3X4X6V	12
	4X4X6V	13
6V Mono-Blocks (48V)	1X8X6V	14
	2X8X6V	15
	3X8X6V	16
8V Mono-Blocks (24V)	1X3X8V	17
	2X3X8V	18
	3X3X8V	19
	4X3X8V	20

System Configurations (Continued)

Technology	Battery/String configuration (number of strings X number of data points X Nominal voltage of data point)	Configuration Number
8V Mono-Blocks (48V)	1X6X8V	21
	2X6X8V	22
	3X6X8V	23
	4X6X8V	24
12V Mono-Blocks (24V)	1X2X12V	25
	2X2X12V	26
	3X2X12V	27
	4X2X12V	28
12V Mono-Blocks (48V)	1X4X12V	29
	2X4X12V	30
	3X4X12V	31
	4X4X12V	32
16V Mono-Blocks (48V)	1X3X16V	33
	2X3X16V	34
	3X3X16V	35
	4X3X16V	36

4 Alarm Type and PCB Revision/Version Format Appendix

This section describes the details of the alarm type, and PCB revision format settings.

4.1 Alarm Type Format

Data BIT Location and Meaning															
D15	D14	D13	D12	D11	D10	D9	D8	D7	D6	D5	D4	D3	D2	D1	D0
Parameter				Alarm Status	String number (0 – 15)				Cell number (0 – 127); For Battery System Ground Fault Resistance: 0 = Positive, 1 = Negative						

Parameter Name	Value
Cell voltage	0
Cell temperature	1
Cell resistance	2
Cell intercell	3
Overall voltage	4
String current	5
Float current	6
Ripple current	7
Ambient temperature	8
Cell to ambient	9
Intertier	10
Cell to ambient thermal runaway	11
High float current thermal runaway	12
Ground fault	13
Charger Cable resistance	14
Digital Input	15

Alarm Status	
State	Value
High alarm	1
Low alarm	0

4.2 PCB version/revision format

	Data BIT Location and Meaning							
	Base revision				Sub revision			
	D7	D6	D5	D4	D3	D2	D1	D0
Value	0 – 'A' 1 – 'B' 2 – 'C' 3 – 'D' 4 – 'E' 5 – 'F' 6 – 'G' 7 – 'H'				0 - 15			